

# Preliminary Assessment Report

## Project 3018742, 301 NE NORTHGATE WAY

---

**Assessment Completed:** 10/17/2014

**Project Description:** EDG/SEPA - Construct 122,400 sq ft, 2-story parking structure with 741+ parking stalls.

**Primary Applicant:** [Michael Hartman](#)

This report lists the results of a preliminary assessment of your project requirements by various city departments. It's based on the project characteristics described on your site plan and preliminary application form. If your project required a pre-application site visit (PASV), the results of that site visit are also included. The goal of this report is to help you create a complete submittal package and reduce the need for corrections once your application has been submitted.

### Next Steps

1. Review the requirements in this report and contact the staff members listed below with questions.
2. If a street improvement plan is required, develop and submit it to the Seattle Department of Transportation (SDOT). **The Department of Planning and Development (DPD) will not accept your permit application until your street improvement plan is approved as 60% complete by SDOT. See [SDOT Client Assistance Memo 2213](#) for guidance about the 60% complete approval process.**
3. Schedule an appointment for permit application intake with DPD. **Please bring a copy of this report to your intake appointment.**

### Questions About This Report

If you have questions about the information in this report, contact the appropriate city staff member for each section.

#### DPD Drainage Requirements

Kevin Donnelly, (206) 684-5051, [Kevin.Donnelly@seattle.gov](mailto:Kevin.Donnelly@seattle.gov)

#### DPD Land Use Requirements

Bradley K Wilburn, (206) 615-0508, [Bradley.Wilburn@Seattle.Gov](mailto:Bradley.Wilburn@Seattle.Gov)

#### DPD Preapplication Site Visit Requirements

Roxanne Kennedy, (206) 615-1283, [Roxanne.Kennedy@seattle.gov](mailto:Roxanne.Kennedy@seattle.gov)

#### Seattle City Light Requirements

Ray Ramos, (206) 615-1193, [ray.ramos@seattle.gov](mailto:ray.ramos@seattle.gov)

#### Seattle Department of Transportation Requirements

Yohannes Minas, (206) 733-9044, [yohannes.minas@seattle.gov](mailto:yohannes.minas@seattle.gov)

#### Seattle Public Utilities Requirements

Lan Chau

#### Water Availability

P Kimani, [Karen.Younge@Seattle.Gov](mailto:Karen.Younge@Seattle.Gov)

## Other Resources

- General questions about the permit process: Contact the DPD Applicant Services Center (ASC) at 206-684-8850.
- User-friendly guides to city permitting processes: [DPD](#) and [SDOT](#).
- [Detailed zoning information](#).
- Visit our [permit type pages](#) for step-by-step instructions and forms for preparing your application and plans for review.

## Requirements

### **DPD Drainage Requirements**

The following requirements are based on the current stormwater and side sewer codes.

#### **Existing Public Drainage Infrastructure**

Sanitary sewer main location: On-site private main

Sanitary sewer main size: 12-inches

Storm drainage main location: On-site private main

Storm drainage main size: 30-inches

#### **Drainage**

The drainage point of discharge (SMC 22.805.020) is located at: Other. Private storm main

#### **Flow Control Compliance**

All new, replaced, and disturbed topsoil shall be amended with organic matter per rules promulgated by the Director prior to completion of the project to improve onsite management of drainage water flow and water quality per SMC 22.805.020.E. A completed [Construction Stormwater Control and Soil Amendment Standard Plan](#) is required.

Parcel-based projects with 7,000 square feet or more of land disturbing activity or 2,000 square feet or more of new plus replaced impervious surface must implement green stormwater infrastructure (bioretention cells, green roofs, permeable pavement, rainwater harvesting, etc.) to infiltrate, disperse, and retain drainage water onsite to the maximum extent feasible per SMC 22.805.020.F. and [Director's Rule 15-2012](#).

Flow control standards must be first met by utilizing green stormwater infrastructure to the maximum extent feasible. Additional flow control measures shall be installed if the flow control standard cannot be met solely using green stormwater infrastructure. Refer to [DR 17-2009](#). Submit a [Green Stormwater Requirement Calculator](#) along with additional flow control documentation.

For more information see: <http://www.seattle.gov/dpd/codesrules/codes/stormwater/default.htm>

This project site also discharges into a capacity-constrained system (SMC 805.050.A.6). In addition to meeting Pre-developed Forest or Pasture Standard, this project shall also comply with 22.805.080.B4 (Peak Control Standard). The post-development peak flow with a 4% annual probability (25-year recurrence flow) shall not exceed 0.4 cubic feet per second per acre. Additionally, the peak flow with a 50% annual probability (2-year recurrence flow) shall not exceed 0.15 cubic feet per second per acre.

Projects with less than 10,000 sf new plus replaced impervious surface can use the [Pre-Sized Flow Control Calculator](#) in lieu of continuous modeling.

This project site discharges to a Non-listed Creek Basin (SMC 805.050.A.3) and shall provide flow control meeting the Pre-developed Pasture Standard per [SMC 22.805.080.B.3](#).

Projects with less than 10,000 sf new plus replaced impervious surface can use the [Pre-Sized Flow Control Calculator](#) in lieu of continuous modeling.

#### **Water Quality**

This project site discharges to a water body that requires basic treatment (SMC 22.805.050 B). Based upon the information provided on the Preliminary Application Form pertaining to existing and proposed impervious surfacing this project shall: provide a basic treatment facility that treats the required runoff volume or flow rate from pollution generating surfaces (SMC 22.805.090 B1, B2).

#### **Wastewater**

All homeowners and building owners in King County's service area whose home or building was newly connected to the King County sewer system on or after Feb. 1, 1990 must pay a [King County Capacity Charge](#).

## Permanent and Temporary Dewatering

Per SMC 21.16.110, the proposed project requires a separate side sewer permit for temporary dewatering based on the following: excavation greater than 12 feet deep.

The footing drain (if part of building plan) point of discharge ([DPD DR 4-2011](#)) is located at the following:  
Other. Private storm main

**Projects which propose to permanently discharge groundwater shall comply with Minimum Requirements for Discharges to a Capacity-constrained System, SMC Section 22.805.050.A.6 and SMC Section 22.805.060.A.6. See [DPD Director's Rule 13-2010](#) for more information.**

## DPD Land Use Code Requirements

### Street Requirements

Based on the scope of the proposed project, the following street improvements are required per Chapter 23.53 of the Seattle Municipal Code. Please review Right-of-Way Improvements Manual for design criteria (<http://www.seattle.gov/transportation/rowmanual/manual/>). Show required street improvements on your "enhanced site plan" at DPD permit application intake. If an SDOT Street Improvement Plan (SIP) is required, please list SDOT project number and SDOT contact name on the enhanced site plan. Street Improvement Plans must be accepted by SDOT prior to DPD permit application intake.

#### NE NORTHGATE WAY

Based on the documents provided, no street improvements are required per SMC 23.53.015 and SMC 23.53.006

#### 1ST AVE NE

Based on the documents provided, no street improvements are required per SMC 23.53.015 and SMC 23.53.006

#### NE 103RD ST

Street trees shall be provided in the planting strip according to Seattle Department of Transportation Tree Planting Standards. Contact SDOT Urban Forestry (for residential projects: (206) 684-TREE; for all others: (206) 684-5693), to determine species of tree and standards of planting. Please add a note to the site plan showing size, location and species of tree to be planted.  
<http://www.seattle.gov/transportation/treeplanting.htm>.

Any planting proposed within the ROW must be reviewed and approved by DPD and SDOT.

A 1.5 foot setback is required. Please label on Site Plan.

### Land Use

Based on the project scope. SEPA may be required. See DPD Director's Rule 12-2012 for more details (<http://web1.seattle.gov/dpd/dirrrulesviewer/>).

Design Review is required; see CAM 238 for more details. Departures from development standards should be identified as early as possible in the application process.

Preliminary screening of your project has been completed and it appears that your proposal is located in an environmentally critical area (ECA) which may require an ECA review and SEPA. For additional information about ECAs and SEPA, visit the DPD website (<http://www.seattle.gov/dpd/Codes/>).

### Other Requirements

A presubmittal conference is required before to submitting an application. Details for preparing and submitting a presubmittal request form can be found at our Web site ([http://www.seattle.gov/dpd/Publications/Forms/Building Permits/default.asp](http://www.seattle.gov/dpd/Publications/Forms/Building_Permits/default.asp)).

## Pre-Application Site Visit (PASV) Requirements

PASV report requirements may be subject to additions, changes, or modifications by the department. The purpose of the report is to alert the applicant that there may be unusual or complex site conditions that trigger requirements from the department regarding this project. **The applicant is responsible for providing all required documents at the intake appointment.** If you have questions about this report or the PASV process, please contact the DPD Site Development Team at (206) 684-8860.

**Note:** Any project application associated with the development site can utilize the results from this PASV if the application is accepted by DPD within 24 months of the above inspection date. After 24 months, the applicant must apply for another PASV. No extensions will be granted.

### ECA Mapping Unit and Type

This project site appears to include the following ECAs and/or buffers:

Steep slope

## **Earth Disturbance**

If excavation has the potential to encroach on adjacent property in order to facilitate construction activity, please provide documentation of consent from the adjacent property owner. Show area of proposed encroachment on the submitted drawings and detailed cross-sections.

If temporary cuts greater than 1h:1v will be required in order to facilitate construction activity, please provide a geotechnical engineer's verification that soil conditions allow cuts to stand unsupported. Include detailed cross sections.

Please show all existing and proposed retaining walls/rockeries and the exposed height.

If shoring will be required, please provide submittals by geotechnical and structural engineers and show the proposed system on the submitted drawings. Include detailed cross sections.

## **Existing ROW Conditions**

### **NE NORTHGATE WAY**

Street conditions:

Visible pavement width is: Not applicable

Curb conditions:

### **1ST AVE NE**

### **NE 103RD ST**

## **Tree Protection**

Trees greater than 6 inches in diameter as measured 4.5 ft above ground are present on the site but not shown on the site plan. Show the dripline of

- 1) **all** trees on the site,
- 2) adjacent trees that encroach on the site that are greater than 6 inches in diameter as measured 4.5 ft above ground, and
- 3) **all** trees located in the adjacent ROW.

Include common and scientific names for all trees shown. For more information, see [Director's Rule 16-2008](#) and [Tip 242](#).

## **Construction Stormwater Control**

All projects with earth disturbance, regardless of size, require temporary and permanent stormwater control in accordance with the Construction Stormwater Control (CSC) Technical Requirements Manual ([DR 16-2009, Volume 2](#)).

**Show the following on the [Construction Stormwater Control and Soil Amendment Standard Plan](#):**

Place filter fabric, straw bales, straw wattles, or other approved equal to control construction stormwater runoff. Required along the following property lines:

Place compost socks, compost berms, filter fabric fencing, straw bales, straw wattles, or other approved perimeter control BMPs to eliminate construction stormwater runoff.

Show the location of a stabilized construction access to the site; show methods to eliminate uncontrolled conveyance of mud and dirt into the right of way (ROW).

Cover bare soil with compost blankets, straw, mulch, matting, or other approved equal to control construction stormwater runoff.

Cover stockpiles and bare slopes with compost blankets, tarps, matting or other approved equal to control construction stormwater runoff.

A First Ground Disturbance inspection is required before any ground disturbance related to this permit, including demolition, tree cutting, clearing, grubbing, and grading. After your permit is issued, schedule an inspection by calling (206) 684-8900 or [online](#) at <http://web1.seattle.gov/DPD/InspectionRequest/default.aspx>.

## **Inspectors Notes**

Some of the smaller bio-cells will be deleted for this project.

## **Small Project Waivers (See CAM 327B)**

Small project waivers may be applicable for new accessory structures or additions to buildings on lots in existence on or before October 31, 1992 (see SMC25.09.055). Rockeries and retaining walls do not qualify for small project waivers. Applicability of small project waiver must be evaluated and approved at the time of intake.

Cumulative development area is less than or equal to the following:

Steep slope areas/steep slope buffers: Development area less than 300 square feet

**In all cases, show construction safety fencing separating the ECA and/or its buffer from the development area.**

## **Standard Submittal Requirements for Projects in an ECA**

Submit a geotechnical report with the permit intake submittal package. Geotechnical report must be signed and stamped by a geotechnical engineer licensed in the State of Washington per [SMC 22.170.070](#), [SMC 25.09](#), and [Directors Rule \(DR\) 18-2011](#).

Provide a topographic survey with 2-foot contours on and within 25-feet of the property, stamped by a licensed land surveyor (see [25.09.330A](#))

Delineate the clearing limits on the site plan

Provide a vegetation restoration plan per SMC [25.09.320](#), [Tip 331](#) and [Tip 331A](#). **Prior to any vegetation removal in the critical area, review, approval, and a preconstruction meeting is required**

Delineate the steep slope critical area on a site plan based on the survey (per SMC 25.09.020 A3b(5)).

Provide area calculations for the steep slope delineation.

Show the steep slope buffer. Generally, the buffer is 15-feet from the top and/or toe of the slope

Construction activity area appears to be within the steep slope critical area and/or its associated buffer. A steep slope variance may be required (see SMC 25.09.180E.1)

An ECA pre-submittal conference is strongly recommended. Call the Applicant Services Center (206-684-8850) to schedule an appointment

## **Seattle City Light Requirements**

### **Street/Alley Requirements NE NORTHGATE WAY**

Underground electrical facilities/conductors require separation from other utilities. Review SCL Construction Guideline U2-10/NDK-50, Electrical Conduit and Facilities in the Public Rights of Way (<http://www.seattle.gov/Light/engstd/>). Before digging, contact the Utilities Underground Location Center ("one-call") at (800) 424-5555 two business days in advance to locate and mark underground utilities, per state law (RCW 19.122). There are underground high voltage lines and electrical facilities along NE Northgate Way.

### **1ST AVE NE**

Working Clearance: State law requires construction workers, their tools, machinery, equipment, and materials to maintain a 10-foot clearance from power lines. Review WAC 296-24-960 and OSHA 1910.333(c)(3)(i). Transmission lines require greater clearance. To work near power lines, notify SCL well in advance to de-energize and ground the lines, or relocate the lines temporarily. This SCL work is done at the project's expense. There are overhead high voltage lines, including transmission, along 1st Ave NE.

### **NE 103RD ST**

Working Clearance: State law requires construction workers, their tools, machinery, equipment, and materials to maintain a 10-foot clearance from power lines. Review WAC 296-24-960 and OSHA 1910.333(c)(3)(i). Transmission lines require greater clearance. To work near power lines, notify SCL well in advance to de-energize and ground the lines, or relocate the lines temporarily. This SCL work is done at the project's expense. There are overhead high voltage lines along NE 103rd St.

### **Easements**

SCL power easement may be required. Property survey may be required at project's expense.

### **Other Requirements**

- City Light has existing underground electrical lines and vaults in the area of the proposed new structure. If relocation is required, power outages to surrounding businesses may occur. For new service or revised electrical service, please contact the Electrical Service Representative for your area several months before new service is required to determine your electric service design, service location and what kind of service is available at the building site. An Application for Electrical Service must be submitted to Seattle City Light. The Electrical Service Representative should also be contacted to coordinate electrical disconnections prior to demolition and temporary power for construction. Your Electrical Service Representative is: Dave Kylen, 206-615-0607, [david.kylen@seattle.gov](mailto:david.kylen@seattle.gov). Be advised that it is the applicant's responsibility to seek guidance from SCL. Failure to contact SCL early in the permit process could severely impact your project's scope, schedule and budget. This responsibility rests solely with the applicant.

## **SDOT Requirements**

Based on the information provided at this time, it appears that no street improvements are **required**. All work in the right-of-way requires a permit. Therefore, if you are planning discretionary improvements you should contact SDOT as soon as possible. Be advised that it is the applicant's responsibility to seek guidance from SDOT Street Use should the scope of the project change, or should the applicant become aware of proposed construction in the ROW. Failure to contact SDOT at your earliest convenience could severely impact your project's scope, schedule and budget. This responsibility rests solely with the applicant.

## **SPU Requirements**

### **Water Availability**

Your water availability assessment has been waived.

For all multifamily, commercial, and industrial properties, the requirements for solid waste storage and pickup are outlined in SPU CAM 1301, available on the web at:

[http://www.seattle.gov/util/stellent/groups/public/@spu/@csb/documents/webcontent/cos\\_004542.pdf](http://www.seattle.gov/util/stellent/groups/public/@spu/@csb/documents/webcontent/cos_004542.pdf). For questions about solid waste requirements, contact Liz Kain, (206) 684-4166, [Liz.Kain@seattle.gov](mailto:Liz.Kain@seattle.gov).

### **Other Requirements**

## **Other Requirements**

Owners of residential property occupied by a tenant who will be displaced by housing demolition, substantial rehabilitation, change of use, or removal of use restrictions may need to obtain a Tenant Relocation License. Refer to DPD Tip 123, Seattle's Tenant Relocation Assistance Ordinance, for further information and instructions or call (206) 684-7979.

If your project involves additions or modification to or demolition of an existing building that contains four or more dwelling units or 4,000 square feet or more of non-residential area, and the building is a designated historic landmark or is 50 years old and meets the criteria set forth in SMC 25.12 for landmark designation, SEPA is required. Please contact the Department of Neighborhoods at (206) 684-0228 or [www.seattle.gov/neighborhoods/preservation](http://www.seattle.gov/neighborhoods/preservation) to determine if your building is a designated landmark or if a referral is necessary to determine if the building meets the criteria in SMC 25.12. Refer to Tip 208 for information regarding the application requirements for a SEPA review and Tip 3000 for information regarding landmarks and historic preservation.

If the scope of your proposed project changes before your DPD intake appointment or SDOT street improvement plan application, the requirements in this report may change. If there are municipal code and ordinance changes before our DPD intake appointment, the project must meet the new code requirements. Additional street improvement requirements may be triggered if a permit application for a development project on adjacent property is also undergoing review.

Please be aware that all persons or companies working within the City limits, including all contractors, subcontractors, permit expeditors and other service providers are required to possess a valid City of Seattle business license. This license is required in addition to any other licenses required by the State of Washington, such as a contractors' license or state business license. For more information about City of Seattle business licenses, please contact inspector Michale Crooks at 206-684-8871, [Michale.Crooks@seattle.gov](mailto:Michale.Crooks@seattle.gov), or visit the [Licensing and Tax Administration Division website](#).